

DEPARTMENT OF TRANSPORTATION - District 4 Toll Bridge Program

333 Burma Rd.

Oakland, CA 94607

(510) 622-5660, (510) 286-0550 fax

*Flex your power
Be energy efficient!*

December 31, 2007

Contract No. 04-0120F4

04-SF-80-13.2 / 13.9

Self-Anchored Suspension Bridge

Letter No. 05.03.01-001071

Michael Flowers
Project Executive
American Bridge/Fluor Enterprises, a JV
375 Burma Road
Oakland, CA 94607

Dear Michael Flowers,

Submittal 168, Rev. 2 – MFSQA for Tower Diaphragm Reinforcing Flange

The Department has completed review of Submittal ABF-SUB-000168R02, "Request for ZPMC Tower Diaphragm Reinforcing Flange MFSQA," dated December 18, 2007.

The MFSQA has been submitted as a result of a change (increase) to ZPMC's original scope of work. ZPMC will now heat and bend the tower diaphragm reinforcing flange at their Changxing facility instead of using their approved Subcontractor, Wuxi Huaguang Boiler Co. Ltd., to perform the work.

The MFSQA substantially complies with the Contract and is "Approved." In accordance with Special Provisions Section 8-4, "Audits," the Contractor may schedule a Department audit.

If you have any questions, please contact Dr. Mazen Wahbeh at (818) 292-0659.

Sincerely,

A handwritten signature in blue ink, appearing to read "GPurcell", written over a horizontal line.

GARY PURSELL
Resident Engineer

cc: Rick Morrow, Mark Woods, Gary Lai, Mazen Wahbeh
file: 05.03.01, 55.0168